From:	
FIOIII.	
-	
То:	
CC:	
Li-Li-A	

 Sent:
 1/5/2021 5:01:40 PM

 Subject:
 RE: 2021 Projects with B&V

Classification: Internal

B&V Team,

Below are the notes I received from today's field scoping meeting:

Keswick 1101: Move forward with the Preferred scope except continue OH from LR 1586 all the way to SAP ID 101469508 with 1/0ACSR TW. Harden tap off of fuse 2407 with 1/0ACSR TW.

Konocti 1101: Replace in place. Note on updated key sketch that the conductor between LR 95078 to fuse 6561 will already be replaced with 3-397Al TW under PM# 35117061. We will move forward with replacing in place.

Upper Lake 1101: Remove the "ECOP" from EDRS 2020-82007 title. We will move forward with remote grid option and installing TW between the substation and 472084.

Bucks Creek 1101: There is a chance we may move forward with ALL UG proposal. Customer at Loc F may be relocated (need to talk to Railroad services) to confirm since Remote Grid does not seem like an option. On hold until we can decide whether or not to move forward with ALL UG.

For the projects listed above, the field scoping documents have not been returned to us, but this is something we can start on.

Status	Short Text	Year	Project '
8. Field Review Comments	SH - Upper Lake 1101 CB	2021	
8. Field Review Comments	SH - Keswick 1101 LR 1586	2021	
8. Field Review Comments	SH - Konocti 1102 LR 965078	2021	
8. Field Review Comments	SH - Bucks Creek 1101 CB	2021	
8. Field Review Comments	ECOP - LAS GALLINAS A 1105 - H01-LR99904	2021	
10. Sent for Final Approval	ECOP - SILVERADO 2104 - H05-LR726	2021	
8. Field Review Comments	ECOP - FULTON 1107 - H02-LR604	2021	
10. Sent for Final Approval	ECOP - SILVERADO 2102 - H02-LR58626	2021	
10. Sent for Final Approval	ECOP - SILVERADO 2102 - H01-LR58626	2021	

As of now, I have working on key sketches for Middletown 1103 LR 830, and working on key sketches for Putah Creek 1102 & North Dublin 2101.

Thanks.

From:
Sent: Monday, January 4, 2021 09:23


Cc:

Subject: 2021 Projects with B&V


Classification: Internal

B&V Team,

Some of us are getting field scoping documentation comments returned to us. Once the Field Scoping Documentation is returned, please create a new folder within the Hardening folder and create a "Field Scoping" file and save all your previous file in "Job Package" file as shown in the screenshot below:



In the Field Scoping file, please be sure to save all the files sends us, including his email:



Please be sure to review the documents provides and let him know if you concur with the ADE's proposal.

Please review the following Field Scoping Documents below, and know if you concur with the proposal. Once you concur, please create the final key sketch.

Status	Short Text	Year	F
8. Field Review Comments	ECOP - SILVERADO 2102 - H02-LR58626	2021	
8. Field Review Comments	ECOP - LAS GALLINAS A 1105 - H01-LR99904	2021	

8. Field Review Comments	ECOP - SILVERADO 2104 - H05-LR726	2021	
8. Field Review Comments	ECOP - FULTON 1107 - H02-LR604	2021	
8. Field Review Comments	ECOP - SILVERADO 2102 - H01-LR58626	2021	

Once you are done with the Las Gallinas A 1105, please work with on creating the key sketches (3 proposals based on the KMZ) for all four phases on Middletown 1103 LR 830:

Status	Short Text	Year	Project
6. AA Submitted	SH - Middletown 1103 LR 830 PH1	2021	
6. AA Submitted	SH - Middletown 1103 LR 830 PH2	2021	
6. AA Submitted	SH - Middletown 1103 LR 830 PH3	2021	
6. AA Submitted	SH - Middletown 1103 LR 830 PH4	2021	

I created KMZ files & routed the AA for projects below. Please create key sketches (3 proposals based on the KMZ) for all the projects:

Status	Short Text	Year	Project
C. A.A. Codemoitte	OMOD BUTALLORESIA 4400 40040	0004	
6. AA Submitted	CWSP - PUTAH CREEK 110246012	2021	
6. AA Submitted	CWSP - NORTH DUBLIN 2101 CB	2021	
2 4 4 2 1 3 1 1	OWOD NORTH BURNING OF	0004	
6. AA Submitted	CWSP - NORTH DUBLIN 2101 CB	2021	

Thank you all for the support, I look forward to working with you this year.

Best,