
From: [REDACTED]
To: [REDACTED]
Sent: 3/11/2021 1:43:10 PM
Subject: IR Inspections in HFTD
Attachments: 2021-Wildfire-Safety-Plan.pdf

I just noticed that in our WMP, we say we plan to conduct IR inspections in 1/3 of the HFTD every year. Were you aware of that?

Infrared patrols of overhead assets of distribution in the following recurrence interval:

- HFTD Tier 3 1/3 annually for three years; and
- HFTD Tier 2 1/3 annually three years.