

7/13 6:49 PM

1

Dixie Fire, 2 Acres - 0% Butte County

HWY 70, in Oroville, Butte County, NORTH VALLEY. Tier 3

[39.8518, -121.3933](#)

7/13/2021, 6:48 PM update from CISM: 2 acre vegetation fire surrounded by retardent and a road. Fire is burning in steep terrain with heavy timber. Nothing visible on cameras. Per PSS [redacted] crews will have to hike in or be flown in. Most equipment is staging. PSS [redacted] and SIPT E213 are staging. PSS [redacted] to support remotely. No cell coverage in the canyon. ROCK CREEK-POE - 230 KV, BUCKS CREEK ROCK CREEK CRESTA 230 KV, CARIBOU_ PALERMO 115KV , Bucks Creek 1101 in the area along with the Cresta Dam. (Twitter)

Electric Transmission Asset : ROCK CREEK-POE-230 KVKV, CRESTA-RIO OSO-230 KVKV, BUCKS CREEK-ROCK CREEK-CRESTA-230 KVKV, CARIBOU-TABLE MTN-230 KVKV, CARIBOU-PALERMO-115 KVKV Gas Distribution Main Asset : N

Wildfire Danger Rating is R4 (248)

82°, % Humidity, with a wind speed of 10 MPH, out of the S

OIS#:

Lead Agency: USDA Forest Service, CAPNF - Plumas National Forest

See less



39°51'06.5"N 121°23'35.8"W

Find local businesses, view maps and get driving directions in Google Maps.

www.google.com

▼ Collapse all

7/13 6:51 PM

Initial Epage sent at 1838. Please record as such, [redacted]

1

7/13 6:53 PM

GCC [redacted] and [redacted] notified

1

7/13 7:00 PM

DCC [redacted] notified

1

7/13 7:10 PM

Hydro [redacted] notified

1

7/13 7:31 PM

Epage Update sent at 1930 indicating no change in fire status. Please record, [redacted]

2

7/13 7:53 PM

Dixie Fire Update, fire still holding at just under 2 acres. Calfire has requested PG&E to de-energize the Bucks Creek 1101 at SSD 941 for firefighter safety. Tman [redacted] enroute from Chico with an ETA of 30 minutes

2

7/13 8:21 PM

SIPT E-213 is released returning to Oroville, eta 2200.

1

7/13 8:29 PM

[redacted] is taking over this incident and has been briefed

1

7/13 9:40 PM

Final Epage sent at 21:39

1

7/13 11:25 PM Edited

Per Cal Fire BTU Twitter: "Fire has now grown to 10-15 acres. Ordering additional resources. Access for ground resources is still

1