
From: [REDACTED]
To: [REDACTED]
CC: [REDACTED]
Sent: 7/14/2021 4:50:31 AM
Subject: POTENTIAL CARIBOU ISLAND/OUTAGE

Classification: [Internal](#)

All,

We have reports of a fire near the Feather River corridor in between the Caribou Table Mountain 230 KV Line, Rock Creek Powerhouse, & Cresta Powerhouse. We are discussing, if time permits, what would be necessary to establish an Island with Caribou if the fire was threatening the line to Table. Currently LMUD is already Islanded for planned work, & the Marble Tie is open. Is this possible to plan on short notice? If so, can you please send us requirements given current system conditions as soon as you can. Additionally, we have to consider the loss of all area Gen & those potential operational impacts in the area.

Thank You.

[REDACTED]
GCC NS