

From: [REDACTED]
To: [REDACTED]
Sent: 7/14/2021 6:18:50 AM
Subject: Updated: Elevated Fire Potential Index for 07/14/21

CONFIDENTIAL TRANSMISSION INFORMATION - DO NOT SHARE WITH PG&E ENERGY SUPPLY EMPLOYEES AND DO NOT FORWARD

Update: Elevated Fire Potential Index for 07/14/21

**FIA 175 moved from R4 to R3.
FIA 411 and 427 moved from R5 to R4.**

R4: (55)
177, 241, 243, 244, 245, 246, 247, 248, 249, 250, 255, 262, 280, 282, 285, 290, 293, 300, 305, 320, 330, 335, 340, 345, 348, 350, 360, 370, 385, 400, 411, 420, 424, 427, 428, 430, 438, 440, 448, 450, 490, 497, 525, 535, 540, 545, 560, 565, 570, 575, 580, 585, 588, 590, 651

R5: (2)
445, 495

R5+: (0)
None

Total lines per voltage level to be tested in accordance with [TD-1464P-01](#):
115kV Lines: 84
70kV Lines: 28
60kV Lines: 93

Additionally, auto-reclosing will be disabled on (70) 230kV lines in these areas if they experience a momentary interruption.

North State

Area 241:

- DELTA-MTN GATE JCT 60kV line
- KESWICK-TRINITY 60kV line
- CRAG VIEW-CASCADE 115kV line
- TRINITY-COTTONWOOD 115kV line

Area 244:

- CLOVER CREEK 60kV tap
- KILARC-CEDAR CREEK 60kV line
- KILARC-DESCHUTES 60kV line
- VOLTA-DESCHUTES 60kV line
- VOLTA-SOUTH 60kV line
- BLACK 230kV tap

CARBERRY SW STA-ROUND MTN 230kV line
COVE ROAD 230kV tap
PIT #1-COTTONWOOD 230kV line
PIT #3-CARBERRY SW STA 230kV line
PIT #3-PIT #1-230kV line
PIT #4 230kV tap
PIT #5-ROUND MTN #1-230kV line
PIT #5-ROUND MTN #2-230kV line
PIT #6 JCT-ROUND MTN 230kV line
PIT #6 230kV tap
PIT #7 230kV tap
ROUND MTN-COTTONWOOD #2-230kV line
ROUND MTN-COTTONWOOD #3-230kV line

Area 245:

ELK CREEK 60kV tap
BRIDGEVILLE-COTTONWOOD 115kV line

Area 246:

CASCADE-BENTON-DESCHUTES 60kV line
COLEMAN-COTTONWOOD 60kV line
COLEMAN-RED BLUFF 60kV line
COLEMAN-SOUTH 60kV line
COTTONWOOD #1-60kV line
COTTONWOOD #2-60kV line
COTTONWOOD-BENTON #1-60kV line
COTTONWOOD-BENTON #2-60kV line
COTTONWOOD-RED BLUFF 60kV line
DELTA-MTN GATE JCT 60kV line
ELK CREEK 60kV tap
KESWICK-CASCADE 60kV line
KESWICK-TRINITY 60kV line
KILARC-DESCHUTES 60kV line
KILARC-VOLTA TIE 60kV line
MTN GATE JCT-CASCADE 60kV line
MTN GATE 60kV tap
VOLTA-DESCHUTES 60kV line
WINTU 60kV tap
BRIDGEVILLE-COTTONWOOD 115kV line
CASCADE-COTTONWOOD 115kV line
COTTONWOOD-PANORAMA 115kV line
CRAG VIEW-CASCADE 115kV line

JESSUP 115kV tap
TRINITY-COTTONWOOD 115kV line
PIT #1-COTTONWOOD 230kV line
ROUND MTN-COTTONWOOD #2-230kV line
ROUND MTN-COTTONWOOD #3-230kV line
COTTONWOOD-DELEVAN #1-230kV line
COTTONWOOD-DELEVAN #2-230kV line
COTTONWOOD-GLENN 230kV line
COTTONWOOD-LOGAN CREEK 230kV line
COLEMAN HATCHERY 60kV tap

Area 247:

COLEMAN-SOUTH 60kV line
KILARC-CEDAR CREEK 60kV line
KILARC-DESCHUTES 60kV line
VOLTA-DESCHUTES 60kV line
VOLTA-SOUTH 60kV line
PIT #1-COTTONWOOD 230kV line
ROUND MTN-COTTONWOOD #2-230kV line
ROUND MTN-COTTONWOOD #3-230kV line

Area 248:

CARIBOU-PALERMO 115kV line
GRIZZLY 115kV tap
GRIZZLY 115kV tap (SVP)
BUCKS CREEK-ROCK CREEK-CRESTA 230kV line
CARIBOU-TABLE MTN 230kV line
CRESTA-RIO OSO 230kV line
ROCK CREEK-POE 230kV line

Area 249:

HAT CREEK #1-WESTWOOD 60kV line
HAT CREEK #1-PIT #1-60kV line
PIT #1-HAT CREEK #2-BURNEY 60kV line
PIT #1-MCARTHUR 60kV line
CARBERRY SW STA-ROUND MTN 230kV line
PIT #1-COTTONWOOD 230kV line
PIT #3-CARBERRY SW STA 230kV line
PIT #3-PIT #1-230kV line
MALACHA 230kV tap
SPI (BURNEY) 230kV tap
BURNEY 60kV tap
BURNEY FOREST PRODUCTS 230kV tap

Area 250:

HAT CREEK #1-WESTWOOD 60kV line

Area 262:

HAT CREEK #1-WESTWOOD 60kV line

Area 280:

CENTERVILLE-TABLE MTN 60kV line

CENTERVILLE-TABLE MTN-OROVILLE 60kV line

COLGATE-PALERMO 60kV line

DESABLA-CENTERVILLE 60kV line

FORKS OF THE BUTTE 60kV tap

ORO FINO 60kV tap

PALERMO-OROVILLE #1-60kV line

PALERMO-OROVILLE #2-60kV line

CARIBOU-PALERMO 115kV line

PALERMO-NICOLAUS 115kV line

PALERMO-PEASE 115kV line

PALERMO-WYANDOTTE 115kV line

PALERMO-BOGUE 115kV line

PARADISE-BUTTE 115kV line

PARADISE-TABLE MTN 115kV line

WOODLEAF-PALERMO 115kV line

CARIBOU-TABLE MTN 230kV line

CRESTA-RIO OSO 230kV line

PALERMO-COLGATE 230kV line

POE-RIO OSO 230kV line

ROCK CREEK-POE 230kV line

TABLE MTN-PALERMO 230kV line

TABLE MTN-RIO OSO 230kV line

OROVILLE-TABLE MOUNTAIN 230kV line (CDWR)

OROVILLE-THERMALITO-TABLE MOUNTAIN #1-230kV line
(CDWR)

OROVILLE-THERMALITO-TABLE MOUNTAIN #3-230kV line
(CDWR)

Area 282:

COLGATE-CHALLENGE 60kV line

FORBESTOWN 115kV tap

KANAKA 115kV tap

SLY CREEK 115kV tap

WOODLEAF-PALERMO 115kV line

Area 285:

CARIBOU #2-60kV line

CARIBOU-PLUMAS JCT 60kV line

CARIBOU-WESTWOOD 60kV line
PLUMAS-SIERRA 60kV tap
CARIBOU-PALERMO 115kV line
BUTT VALLEY-CARIBOU 115kV line
GRIZZLY 115kV tap
CARIBOU-TABLE MTN 230kV line
ROCK CREEK-POE 230kV line
BELDEN 230kV tap
SIERRA PAC IND (QUINCY) 60kV tap

Area 290:

CARIBOU-WESTWOOD 60kV line
HAMILTON BRANCH-CHESTER 60kV line
HAT CREEK #1-WESTWOOD 60kV line
COLLINS PINE 60kV tap
BUTT VALLEY-CARIBOU 115kV line

Area 300:

BEALE AFB (WAPA) #1-60kV tap
BEALE AFB (WAPA) #2-60kV tap
COLGATE-SMARTVILLE #1-60kV line
COLGATE-SMARTVILLE #2-60kV line
NARROWS #1-60kV tap
NARROWS #2-60kV tap
SMARTVILLE 60kV tap
SMARTVILLE-CAMP FAR WEST 60kV line
SMARTVILLE-MARYSVILLE 60kV line
SMARTVILLE-NICOLAUS #1-60kV line
SMARTVILLE-NICOLAUS #2-60kV line
COLGATE-RIO OSO 230kV line
PALERMO-COLGATE 230kV line

Area 330:

COLGATE PH-COLGATE SW STA 60kV line (YCWA CONTROLLED)
COLGATE-ALLEGHANY 60kV line
COLGATE-CHALLENGE 60kV line
COLGATE-GRASS VALLEY 60kV line
COLGATE-PALERMO 60kV line
COLGATE-SMARTVILLE #1-60kV line
COLGATE-SMARTVILLE #2-60kV line
PALERMO-COLGATE 230kV line
COLGATE-RIO OSO 230kV line

Area 350:

COLGATE-ALLEGHANY 60kV line

North Bay Sierra

Area 177:

CORTINA-MENDOCINO #1-115kV line

EAGLE ROCK-CORTINA 115kV line

FULTON JCT-VACA 115kV line

FULTON-PUEBLO 115kV line

MADISON-VACA 115kV line

MONTICELLO PH 115kV tap

SILVERADO-FULTON JCT 115kV line

VACA-SUISUN 115kV line

VACA-SUISUN-JAMESON 115kV line

VACA-VACAVILLE-CORDELIA 115kV line

VACA-VACAVILLE-JAMESON-NORTH TOWER 115kV line

CORTINA-VACA 230kV line

DELEVAN-VACA #1-230kV line

DELEVAN-VACA #2-230kV line

DELEVAN-VACA #3-230kV line

TULUCAY-VACA 230kV line

VACA-BAHIA 230kV line

VACA-LAKEVILLE #1-230kV line

VACA-PARKWAY 230kV line

Area 300:

HALSEY-PLACER 60kV line

PLACER-DEL MAR 60kV line

BELL-PLACER 115kV line

DRUM-HIGGINS 115kV line

DRUM-RIO OSO #1-115kV line

DRUM-RIO OSO #2-115kV line

FLINT 115kV tap

HIGGINS-BELL 115kV line

MTN QUARRIES 60kV tap

PLACER-GOLD HILL #1-115kV line

PLACER-GOLD HILL #2-115kV line

AUBURN 60kV tap

Area 305:

GOLD HILL #1-60kV line

MISSOURI FLAT-GOLD HILL #1-115kV line

MISSOURI FLAT-GOLD HILL #2-115kV line

MIDDLE FORK-GOLD HILL 230kV line

Area 330:

CAPE HORN 60kV tap
DEER CREEK-DRUM 60kV line
DRUM-GRASS VALLEY-WEIMAR 60kV line
MIDDLE FORK #1-60kV line
OXBOW 60kV tap
ROLLINS 60kV tap
WEIMAR #1-60kV line
WEIMAR-HALSEY 60kV line
BRUNSWICK #1-115kV tap
BRUNSWICK #2-115kV tap
DRUM-HIGGINS 115kV line
DRUM-RIO OSO #1-115kV line
DRUM-RIO OSO #2-115kV line
DUTCH FLAT #2-115kV tap
MIDDLE FORK-GOLD HILL 230kV line

Area 335:

FRENCH MEADOWS-MIDDLE FORK 60kV line
APPLE HILL #1-115kV tap
APPLE HILL #2-115kV tap
EL DORADO-MISSOURI FLAT #1-115kV line
EL DORADO-MISSOURI FLAT #2-115kV line
MIDDLE FORK #1-60kV line
MIDDLE FORK-GOLD HILL 230kV line

Area 340:

MIDDLE FORK-GOLD HILL 230kV line
APPLE HILL #1-115kV tap
APPLE HILL #2-115kV tap
DRUM-GRASS VALLEY-WEIMAR 60kV line
EL DORADO-MISSOURI FLAT #1-115kV line
EL DORADO-MISSOURI FLAT #2-115kV line
GOLD HILL #1-60kV line
HALSEY-PLACER 60kV line
HIGGINS-BELL 115kV line
MISSOURI FLAT-GOLD HILL #1-115kV line
MISSOURI FLAT-GOLD HILL #2-115kV line
MTN QUARRIES 60kV tap
WEIMAR #1-60kV line
WEIMAR-HALSEY 60kV line

Area 350:

DEER CREEK-DRUM 60kV line
DRUM-GRASS VALLEY-WEIMAR 60kV line
DRUM-SPAULDING 60kV line
FRENCH MEADOWS-MIDDLE FORK 60kV line
SPAULDING #3-SPAULDING #1-60kV line
SPAULDING-SUMMIT 60kV line
DRUM PH #2-115kV tap
DRUM-HIGGINS 115kV line
DRUM-RIO OSO #1-115kV line
DRUM-RIO OSO #2-115kV line
DRUM-SUMMIT #1-115kV line
DRUM-SUMMIT #2-115kV line

Bay Area Metro

Area 540:

NORTH DUBLIN-VINEYARD 230kV line
LAS POSITAS-NEWARK 230kV line

South Coast

Area 495:

TEMPLETON-GATES 230kV line
CALIFORNIA FLATS SW STA-GATES 230kV line

Area 497:

CALIFORNIA FLATS SW STA-GATES 230kV line
MORRO BAY-CALIFORNIA FLATS SW STA 230kV line
TEMPLETON-GATES 230kV line

Area 525:

COBURN-LAS AGUILAS SW STA 230kV line
CRAZY HORSE CANYON-SALINAS-SOLEDAD #1-115kV line
CRAZY HORSE CANYON-SALINAS-SOLEDAD #2-115kV line
MOSS LANDING-COBURN 230kV line
MOSS LANDING-LAS AGUILAS SW STA 230kV line

Area 535:

LOS ESTEROS-METCALF 230kV line

Area 545:

COBURN-LAS AGUILAS SW STA 230kV line
MOSS LANDING-LAS AGUILAS SW STA 230kV line

Area 560:

LAURELES-OTTER 60kV line

Area 565:

JOLON 60kV tap

Area 570:

JOLON 60kV tap

Area 575:

ATASCADERO-SAN LUIS OBISPO 70kV line

ATASCADERO-CAYUCOS 70kV line

MORRO BAY-CALIFORNIA FLATS SW STA 230kV line

MORRO BAY-TEMPLETON 230kV line

TEMPLETON-ATASCADERO 70kV line

Area 580:

COALINGA #1-SAN MIGUEL 70kV line

MORRO BAY-CALIFORNIA FLATS SW STA 230kV line

TEMPLETON-GATES 230kV line

Area 585:

SISQUOC-GAREY 115kV line

Area 590:

MORRO BAY-SOLAR SW STA #1-230kV line

MORRO BAY-SOLAR SW STA #2-230kV line

Central Valley**Area 305:**

BUENA VISTA BIOMASS POWER 60kV tap

CLAY-MARTEL 60kV line

IONE 60kV tap

PARDEE #1-60kV tap

PARDEE #2-60kV tap

VALLEY SPRINGS-CLAY 60kV line

Area 320:

NEW HOGAN 60kV tap

PARDEE #1-60kV tap

VALLEY SPRINGS #1-60kV line

VALLEY SPRINGS #2-60kV line

VALLEY SPRINGS-CALAVERAS CEMENT 60kV line

VALLEY SPRINGS-CLAY 60kV line

BELLOTA-RIVERBANK-MELONES SW STA 115kV line

CHINESE CAMP (ULTRA POWER) 115kV tap

COTTLE-MELONES 230kV line

ELECTRA-BELLOTA 230kV line

FROGTOWN #1-115kV tap

FROGTOWN #2-115kV tap

MELONES-CURTIS 115kV line

MELONES-RACETRACK 115kV line

MELONES-WILSON 230kV line
TIGER CREEK-VALLEY SPRINGS 230kV line
PEORIA 115kV tap
RACETRACK 115kV tap
STANISLAUS-MANTECA #2-115kV line
STANISLAUS-MELONES SW STA-MANTECA #1-115kV line
STANISLAUS-MELONES SW STA-RIVERBANK JCT SW STA
115kV line
TULLOCH 115kV tap
VALLEY SPRINGS-BELLOTA 230kV line
VALLEY SPRINGS-MARTELL #1-60kV line
WEST POINT-VALLEY SPRINGS 60kV line

Area 335:

KM GREEN 115kV tap
SALT SPRINGS-TIGER CREEK 115kV line
TIGER CREEK-ELECTRA 230kV line
TIGER CREEK-VALLEY SPRINGS 230kV line

Area 340:

CLAY-MARTELL 60kV line
ELECTRA-BELLOTA 230kV line
PINE GROVE 60kV tap
TIGER CREEK-ELECTRA 230kV line
TIGER CREEK-VALLEY SPRINGS 230kV line
VALLEY SPRINGS-MARTELL #1-60kV line
WEST POINT-VALLEY SPRINGS 60kV line
AMFOR 60kV tap

Area 345:

PARDEE #1-60kV tap
VALLEY SPRINGS-CLAY 60kV line
VALLEY SPRINGS-MARTELL #1-60kV line
WEST POINT-VALLEY SPRINGS 60kV line
STANISLAUS-MANTECA #2-115kV line
STANISLAUS-MELONES SW STA-MANTECA #1-115kV line
STANISLAUS-MELONES SW STA-RIVERBANK JCT SW STA
115kV line
TIGER CREEK-ELECTRA 230kV line
TIGER CREEK-VALLEY SPRINGS 230kV line
ELECTRA-BELLOTA 230kV line

Area 348:

MI-WUK-CURTIS 115kV line
DONNELLS-MI-WUK 115kV line
FIBREBOARD STANDARD 115kV tap

MELONES-CURTIS 115kV line
MELONES-RACETRACK 115kV line
RACETRACK 115kV tap

Area 360:

BEARDSLEY 115kV tap
KM GREEN 115kV tap
SALT SPRINGS-TIGER CREEK 115kV line

Area 370:

BEARDSLEY 115kV tap
DONNELLS-MI-WUK 115kV line
SANDBAR 115kV tap
SPRING GAP 115kV tap

Area 400:

MCSWAIN 70kV tap
MERCED FALLS-EXCHEQUER 70kV line

Area 420:

BRICEBURG JCT-MARIPOSA 70kV tap
EXCHEQUER-MARIPOSA 70kV line
EXCHEQUER-INDIAN FLAT 70kV line
INDIAN FLAT-YOSEMITE 70kV line

Area 424:

CHOWCHILLA-KERCKHOFF #2-115kV line
OAKHURST 115kV tap

Area 427:

CHOWCHILLA-KERCKHOFF #2-115kV line

Area 490:

DINOSAUR POINT 70kV tap
LOS BANOS-PACHECO 70kV line

Area 540:

TESLA-SALADO #1-115kV line
TESLA-SALADO-MANTECA 115kV line
QUINTO SW STA-WESTLEY 230kV line
TESLA-NEWARK #1-230kV line
TESLA-NEWARK #2-230kV line
TESLA-RAVENSWOOD 230kV line

South Valley

Area 411:

TULE-SPRINGVILLE 70kV line (SCE)

Area 424:

AUBERRY 70kV tap

HELMS-GREGG #1-230kV line
HELMS-GREGG #2-230kV line
KERCKHOFF-CLOVIS-SANGER #1-115kV line
KERCKHOFF-CLOVIS-SANGER #2-115kV line
WISHON-COPPERMINE 70kV line
WISHON-SAN JOAQUIN #3-70kV line
YANKE (NORTH FORK) 70kV tap (IDLE)

Area 427:

WISHON-COPPERMINE 70kV line
WISHON-SAN JOAQUIN #3-70kV line
KERCKHOFF-CLOVIS-SANGER #1-115kV line
KERCKHOFF-CLOVIS-SANGER #2-115kV line
KERCKHOFF #1-KERCKHOFF #2-115kV line

Area 428:

HAAS-WOODCHUCK 70kV line
BALCH-SANGER 115kV line
KINGS RIVER-SANGER-REEDLEY 115kV line
BALCH-MCCALL 230kV line
HAAS-MCCALL 230kV line
HELMS-GREGG #1-230kV line
HELMS-GREGG #2-230kV line

Area 430:

COPPERMINE-TIVY VALLEY 70kV line
DUNLAP 70kV tap
BALCH-SANGER 115kV line
KINGS RIVER-SANGER-REEDLEY 115kV line
BALCH-MCCALL 230kV line
HAAS-MCCALL 230kV line
PINE FLAT PH 230kV tap (CDWR)

Area 438:

TULE-SPRINGVILLE 70kV line (SCE)
VEDDER 70kV tap

Area 440:

TULE-SPRINGVILLE 70kV line (SCE)
DUNLAP 70kV tap

Area 495:

ARCO-CHOLAME 70kV line
ARCO-POLONIO PASS PP 70kV line
COALINGA #1-SAN MIGUEL 70kV line

Area 497:

COALINGA #1-SAN MIGUEL 70kV line

Area 590:

TEMBLOR-SAN LUIS OBISPO 115kV line

TAFT-CUYAMA #1-70kV line

TAFT-CUYAMA #2-70kV line

Area 651:

CASTAIC 70kV tap

GRAPEVINE 70kV tap

TEJON-LEBEC 70kV line



Pacific Gas & Electric
Operations Supervisor
Electric Operations-Grid Control Center

