- Figure 1	Native Messages chat (chat298377354812293127) :	
	Starting text group anticipating a request to de energize T line. Meeting with IC in 10. When request is confirmed and follow up with call to	1, 11:08 AM Vill text
	Copy on Signal message re Caribou Table 230kV	11:08 AM
	Unread	11:09 AM
	So when you say lots confirming you mean phrase to phase and it will remain out?	11:09 AM
0	It relayed and did not test	11:11 AM
		11:11 AM
0	They will not re-energize	11:11 AM
0	They are working on islanding right now	11:17 AM
	✓ how about the 230 assets in the bottom of the canyon  ? What's their status?	11:18 AM
0	Still energized	11:18 AM
	✓ request may come soon to de-energize. I gave the GCC  a heads up and we'll make that call to GCC when the time comes if that works, I'll be on the 11:30 AM GCC Company.  Output  Description:  Description:	
	We're going to leave the two 230kv lines in the canyon energized for now. Leave Carib off.	11:25 AM ou Table
0	Сору	11:27 AM
	✓ understood per IC leave the 2 230kV lines in the canyon energized	11:28 AM

