

# SWITCHING LOG

Switching Log Number: **21-89419**

NDCC

Purpose: **EAST QUINCY SUB - EMERGENCY OFFLOAD**

OPER NUM	Station or Location	Operation	Apparatus Number	Instructions	Time Given	Executed By Person	Time Executed	Time Reported
1.	GCC	RPTS	---	STARTING SWITCHING TO PLACE CARIBOU INTO ISLAND DUE TO FIRE. REQUEST EAST QUINCY SUB OFFLOADED W/ SW 75 OPEN & REQUEST SPANISH CREEK CB 72 TEMP SETTINGS INSTALLED PER ENGINEERING	---	[REDACTED]	0926	---
2.	NDCC	REQUEST	---	DOE'S PROVIDE SWITCHING PLAN TO OFFLOAD EAST QUINCY SUB AND TEMP SETTINGS FOR SPANISH CREEK CB 72	---	[REDACTED]	0953	---
3.	GCC	RPTS		TBL ON THE CARIBOU-TABLE MOUNTAIN 230KV LINE DUE TO DIXIE FIRE. SUSTAINED OUTAGE TO BIG MEADOWS, CHESTER, CRESCENT MILLS, EAST QUINCY, GANSNER, GRAYS FLAT, HAMILTON BRANCH & SPANISH CREEK SUBS @ 1058. REQUEST ALL CB'S OPEN		[REDACTED]	1102	
4.	BIG MEADOWS SCADA							
5.	↓							
6.	↓							
7.	↓							
8.	↓							
9.	↓							
10.	↓							

Switching Prepared By:	Date:	Switching Checked By:	Date:	Switching Checked by:	Date:	Switching Directed By:	Date:
[REDACTED]	07-14-21						

# SWITCHING LOG


Switching Log Number: 21-89419

Page **2 OF 2**

NDCC

Purpose: **EAST QUINCY SUB - EMERGENCY OFFLOAD**

OPER NUM	Station or Location	Operation	Apparatus Number	Instructions	Time Given	Executed By Person	Time Executed	Time Reported
11.	↓							
12.	↓							
13.	↓							
14.	↓							

Switching Prepared By:	Date:	Switching Checked By:	Date:	Switching Checked by:	Date:	Switching Directed By:	Date:
	07-14-21						