

Created On: Sunday, 08/01/2021

MAN ON LINE



Line Or Apparatus Caribou-Table Mountain 230kV line (Caribou 115/60kV Island)

Limits

Clearance Issued To

By

Reported Clear By

Date/Time

Work Card Number



At

Date/Time

08/01/2021 08:13:00

T21-013110

SWITCHING LOG

Switching Log Number: T21-013110

Page 1 OF 5

GCC NORTH

Purpose: CLEAR THE CARIBOU-TABLE MTN 230KV LINE

TROUBLE

OPER NUM	Station or Location	Operation	Apparatus Number	Instructions	Time Given	Executed By Person	Time Executed	Time Reported
1.	T-LINE	RPTS	—	CAL FIRE CONFIRMS AREA SAFE AND OK FOR PG&E TO PERFORM WORK ON THE CARIBOU-TABLE MOUNTAIN 230KV LINE	—	[REDACTED]	0211	—
2.	GCC NS	CONFIRM	—	BELDEN SW 225 OPEN AND TAGGED MOL VIA EMS	—	[REDACTED]	1453	—
3.	CARIBOU SCADA	CHK	252	OPEN AT CONT AND TAGGED CAUT	L	L	1453	L
4.	TABLE MTN SCADA	CHK	242	ON MAN CONT TAG CAGGED CAUT	L	L	1453	L
5.	↓	CHK	242	OPEN AT CONT AND TAGGED CAUT	L	L	1453	L
6.	CARIBOU	CHK	252	OPEN AT CONT	1453	[REDACTED]	07123 1459	1506
7.	↓	PLACE	252	ON LOCAL TAG CAUT	L	L	1455	L
8.	↓	CHK	252	OPEN IN YARD	L	L	1457	L
9.	↓	OPEN	253	COL&T MOL DE-ENERGIZING	L	L	1459	L
10.	↓	PLACE	252	LINE POT TO GROUNDED POS TAG CAUT	L	L	1500	L
11.	TABLE MTN	CHK	242	OPEN AT CONT	1552	[REDACTED]	1556	1610
12.	↓	CHK	242	ON MAN	L	L	L	L

Internal Switching Prepared By:	Date:	Switching Checked By:	Date:	Switching Checked by:	Date:	Switching Directed By:	Date:
[REDACTED]	7/23/2021					[REDACTED]	7/23/21

SWITCHING LOG

Switching Log Number: T21-013110

Page 2 OF 5

GCC NORTH

Purpose: CLEAR THE CARIBOU-TABLE MTN 230KV LINE

OPER NUM	Station or Location	Operation	Apparatus Number	Instructions	Time Given	Executed By Person	Time Executed	Time Reported
13.	TABLE MTN	PLACE	242	ON LOCAL TAG CAUT	1552	[REDACTED]	1557	1610
14.	↓	CHK	242	OPEN IN YARD			1603	
15.	↓	CHK	245	LOCKED OPEN TAG MOL			L	
16.	↓	OPEN	243	COL&T MOL DEAD OPER			1605	
17.	↓	PLACE	242	LINE POT TO GROUNDED POS TAG CAUT			1609	
18.	GCC NORTH	UPDATE	---	EMS & TOTL	-	[REDACTED]	0813	-
19.	T-LINE CREW	---	---	REPORTS ON THE CARIBOU-TABLE MTN 230KV LINE BET: CARIBOU 253, BELDEN 225, TABLE MTN 243 & 245 USING PER TAILBOARD FORM	-	[REDACTED]	0813	-
20.	↓	---	---	REPORTS OFF THE CARIBOU-TABLE MTN 230KV LINE BET: CARIBOU 253, BELDEN 225, TABLE MTN 243 & 245 WITH PER TAILBOARD FORM				
21.	↓	---	---	CLEARANCE HOLDER CONFIRMS HAS VISUALLY INSPECTED THE CLEARED AREA FOR WORKERS, GROUNDS, AND EQUIPMENT IN THE CLEAR, AND EQUIPMENT IS BEING RETURNED IN THE SAME STATE AS RECEIVED.				
22.	GCC NORTH	UPDATE	---	TOTL				

Internal Switching Prepared By:	Date:	Switching Checked By:	Date:	Switching Checked by:	Date:	Switching Directed By:	Date:
[REDACTED]	7/23/2021					[REDACTED]	7/23/21
						[REDACTED]	8-1-21

SWITCHING LOG


Switching Log Number: T21-013110

Page **3 OF 5**

GCC NORTH

Purpose: **CLEAR THE CARIBOU-TABLE MTN 230KV LINE**

OPER NUM	Station or Location	Operation	Apparatus Number	Instructions	Time Given	Executed By Person	Time Executed	Time Reported
23.	TABLE MTN	CHK	242	OPEN AT CONT				
24.	↓	CHK	242	ON MAN				
25.	↓	CHK	242	ON LOCAL				
26.	↓	CHK	242	OPEN AT SEMAPHORE				
27.	↓	RT CHK	245	LOCKED OPEN				
28.	↓	RT CLO	243	CC&L DEAD OPER				
29.	↓	RT PLACE	242	LINE POT TO UNGROUNDED POS				
30.	↓	RT PLACE	242	ON REMOTE				
31.	CARIBOU	CHK	252	OPEN AT CONT				
32.	↓	CHK	252	ON LOCAL				
33.	↓	CHK	252	OPEN IN YARD				
34.	↓	RT & CLO	253	CC&L ENERGIZING				
35.	↓	RT PLACE	252	LINE POT TO UNGROUNDED POS				
36.	GCC NORTH	NTFY	---	SDV OF INTENT TO RESTORE CARIBOU ISLAND				

Internal Switching Prepared By:	Date:	Switching Checked By:	Date:	Switching Checked by:	Date:	Switching Directed By:	Date:
	7/23/2021						



SWITCHING LOG

Switching Log Number: T21-013110

Page **4 OF 5** GCC NORTH

Purpose: **CLEAR THE CARIBOU-TABLE MTN 230KV LINE**

OPER NUM	Station or Location	Operation	Apparatus Number	Instructions	Time Given	Executed By Person	Time Executed	Time Reported
37.	TABLE MTN SCADA	RT CLO	242	C/CLO ENERGIZE				
38.	↓	CHK	242	LINE POT ON				
39.	GCC NORTH	NTFY	---	CAIRBOU OF INTENT & TO REMOVE UNIT #1 FROM FREQUENCY CONTROL & ADJUST GEN TO SYNC ISLAND				
40.	CARIBOU	CSC & CLO	252	C/CLO SYNC ISLAND				
41.	↓	READ	252	LD				
42.	↓	RT PLACE	252	ON REMOTE				
43.	↓	RT C/IN	---	RAS SW 82				
44.	↓	RT C/IN	---	RAS SW 83				
45.	↓	RT C/IN	252	GEN LD SHEDDING				
46.	GCC NORTH	NTFY	---	SDV OF ISLAND SYNC TIME				
47.	CARIBOU SCADA	RT C/IN	252	CXR				
48.	↓	RT CHK	252	CLO AT CONT				

Internal Switching Prepared By:	Date:	Switching Checked By:	Date:	Switching Checked by:	Date:	Switching Directed By:	Date:
	7/23/2021						
							


SWITCHING LOG

Switching Log Number: T21-013110

Page **5 OF 5** GCC NORTH

Purpose: **CLEAR THE CARIBOU-TABLE MTN 230KV LINE**

OPER NUM	Station or Location	Operation	Apparatus Number	Instructions	Time Given	Executed By Person	Time Executed	Time Reported
49.	CARIBOU SCADA	RT CHK	292	CLO AT CONT				
50.	TABLE MTN SCADA	RT PLACE	242	ON AUTO				
51.	↓	RT C/IN	242	CXR				
52.	↓	RT C/IN	242	DTT TO CARIBOU				
53.	BUTT VALLEY	RT C/IN	---	RAS SW 60				
54.	↓	RT C/IN	---	RAS SW 61				
55.	GCC NORTH	UPDATE	---	EMS & TOTL				
56.	↓	NTFY	---	SPI QUINCY OK TO RETURN TO SERVICE				
57.	↓	NTFY	---	PLUMAS SIERRA OF CONDITIONS, OK TO RESTORE MARBLE TIE IF NEEDED				
58.	↓	NTFY	---	CARIBOU OF CONDITIONS, OK TO RESTORE BUTT VALLEY & CARIBOU UNITS 4 & 5 NORMAL				
59.	CARIBOU	RT C/IN	---	PLUMAS SIERRA SEP SCHEME (IF NEEDED)				

Internal Switching Prepared By:	Date:	Switching Checked By:	Date:	Switching Checked by:	Date:	Switching Directed By:	Date:
	7/23/2021						