




# HAWC Active Fire Summary

Status as of 7/14 at 0830



[CAL FIRE Incidents](#)      [Inci Web USFS](#)

| Active Fire                  | Date/Time Start | Last Incident Update | Acres Burned | Containment | Preliminary Understanding of Cause  | Cust Accounts Impacted | Asset Impacts  |
|------------------------------|-----------------|----------------------|--------------|-------------|---|------------------------|----------------|
| <a href="#">Bootleg Fire</a> | 7/9 1402        | 7/13 0645            | 201,923      | 0%          | Not known. Not in PG&E Service Territory.                                 | 0                      | No PG&E Assets |
| Dixie Fire                   | 7/13 1827       | 7/14 0625            | 100+         | 0%          |   | unknown                |                |
| <a href="#">River Fire</a>   | 7/11 1411       | 7/13 0700            | 9,500        | 15%         | Not known. No initial indication of PG&E assets contributing to the fire. | 173                    | Assessing      |

| Active Fire  | Summary Update  |
|--------------|---|
| Bootleg Fire | The Bootleg Fire continues to burn and threaten the transmission lines from the north. The fire will continue to be extremely active in unchecked portions of the perimeter, with unstable air conditions and extremely dry fuels and likely development of pyro-cumulus. Evacuations are in place.   |
| River Fire   | Firefighters continue to make an aggressive attack on the fire. Forward progress has been slowed significantly. There are structures threatened and evacuations in the immediate area. SIPT has pre-treated 172 poles. The Oakhurst 1101 (117 customers) and Mariposa 2102 (56 customers) are currently impacted. PG&E damage assessment has commenced and will continue today. |
| Dixie        | Dixie Fire is estimated at 100+ acres burning moderately upslope and downcanyon towards Canyon Creek Road and PG&E T-line assets.   |

