




# HAWC Active Fire Summary

Status as of 7/14 at 0830



[CAL FIRE Incidents](#)

[Inci Web USFS](#)

| Active Fire                  | Date/Time Start | Last Incident Update | Acres Burned | Containment | Preliminary Understanding of Cause  | Cust Accounts Impacted | Asset Impacts              |
|------------------------------|-----------------|----------------------|--------------|-------------|---|------------------------|----------------------------|
| <a href="#">Bootleg Fire</a> | 7/9 1402        | 7/13 2155            | 201,923      | 0%          | Not known. Not in PG&E Service Territory.                                 | 0                      | No PG&E Assets             |
| Dixie Fire                   | 7/13 TBD        | 7/14 0625            | 100+         | 0%          | PG&E assets may be involved.  | 3                      | Will need to assess        |
| <a href="#">River Fire</a>   | 7/11 1411       | 7/14 0700            | 9,500        | 25%         | Not known. No initial indication of PG&E assets contributing to the fire. | 173                    | 11 poles<br>2 transformers |

| Active Fire  | Summary Update   |
|--------------|--|
| Bootleg Fire | The Bootleg Fire continues to burn and threaten the transmission lines from the north. The fire will continue to be extremely active in unchecked portions of the perimeter. Significant acreage increase on the eastern side of the fire. Rapid fire spread with high intensity fire behavior due to dry fuels and hot, dry, and unstable atmosphere. Evacuations are in place. |
| Dixie        | Overnight, CAL FIRE did not get good containment on the 2-acre fire. Dixie Fire is now estimated at 100+ acres burning moderately upslope and downcanyon towards Canyon Creek Road and PG&E T-line assets.   |
| River Fire   | Firefighters continue to make an aggressive attack on the fire. Forward progress has been slowed significantly. There are structures threatened and evacuations in the immediate area. SIPT has pre-treated 172 poles. The Oakhurst 1101 (117 customers) and Mariposa 2102 (56 customers) are currently impacted. PG&E damage assessment has commenced and will continue today.  |

