




HAWC Active Fire Summary

Status as of 7/14 at 0830



[CAL FIRE Incidents](#)

[Inci Web USFS](#)

Active Fire	Date/Time Start	Last Incident Update	Acres Burned	Containment	Preliminary Understanding of Cause	Cust Accounts Impacted	Asset Impacts
Bootleg Fire	7/9 1402	7/13 2155	201,923	0%	Not known. Not in PG&E Service Territory.	0	No PG&E Assets
Dixie Fire	7/13 TBD	7/14 0625	100+	0%	PG&E assets may be involved.	3	Will need to assess
River Fire	7/11 1411	7/14 0700	9,500	25%	Not known. No initial indication of PG&E assets contributing to the fire.	173	11 poles 2 transformers

Active Fire	Summary Update
Bootleg Fire	The Bootleg Fire continues to burn and threaten the transmission lines from the north. The fire will continue to be extremely active in unchecked portions of the perimeter. Significant acreage increase on the eastern side of the fire. Rapid fire spread with high intensity fire behavior due to dry fuels and hot, dry, and unstable atmosphere. Evacuations are in place.
Dixie	Overnight, CAL FIRE did not get good containment on the 2-acre fire. Dixie Fire is now estimated at 100+ acres burning moderately upslope and downcanyon towards Canyon Creek Road and PG&E T-line assets.
River Fire	Firefighters continue to make an aggressive attack on the fire. Forward progress has been slowed significantly. There are structures threatened and evacuations in the immediate area. SIPT has pre-treated 172 poles. The Oakhurst 1101 (117 customers) and Mariposa 2102 (56 customers) are currently impacted. PG&E damage assessment has commenced and will continue today.

