

**From:** [REDACTED]  
**To:** [REDACTED]  
**Sent:**  
**Subject:** Dixie Fire Timeline

Hi [REDACTED] –

Operations identified a lack of station service at Cresta Dam yesterday morning and Rock Creek SC notified the North Valley DO.

| Summary     |  |                         |
|-------------|--|-------------------------|
| Update By   | [REDACTED]   | 07/13/2021 08:59 Active |
| Ticket Nmbr | 3114472  |                         |
| Start Time  | 7/13/2021 8:52:00 AM   |                         |
| Location    | ROCK CREEK SWITCHING CENTER  |                         |
| ID Location | CRESTA DAM   |                         |
| Description | [REDACTED] REPORTS THE BUCKS 1101 IS OUT. LIGHTS OUT IN TUNNEL AS WELL AS CRESTA DAM STA SERV. |                         |

| Summary     |  |                         |
|-------------|--|-------------------------|
| Update By   | [REDACTED]   | 07/13/2021 09:12 Active |
| Ticket Nmbr | 3114486  |                         |
| Start Time  | 7/13/2021 9:11:00 AM   |                         |
| Location    | ROCK CREEK SWITCHING CENTER  |                         |
| ID Location | NORTH VALLEY DO  |                         |
| Description | NTFD NVDO/[REDACTED] OF ITEMS 0852 AND 0904. WILL SEND T-MEN TO PATROLL 1101 FROM SUB TO CRESTA DAM. |                         |

The fire was called in to Rock Creek SC at 17:01 and they notified Cal Fire at 17:06.