
From: [REDACTED]
To: [REDACTED]
Sent: 7/14/2021 11:39:37 AM
Subject: Report Out: 1130 Dixie Fire Ops Call

Grid Ops' [REDACTED] opened the call.

At 1058, Caribou-Table Mtn relayed and did not test. Caribou PH1/2 and numerous facilities offline. Probably caused by Dixie Fire.

[REDACTED] Ops Chief: Thick and heavy smoke. Pretty certain that's what relayed that 230kv. No additional request to de-energize at this time. Communication, access are difficult. We are staying out of Cal Fire's way.

[REDACTED] Was in process to making that area an island. Protection in place and line had been floated when the line relayed.

[REDACTED] Disto: We don't have backties.

11,006 customers currently out on 7 outages in OMT.

Engineering has began figuring out how to restore Tlines from a island creation.

[REDACTED] Be cautious about distribution when creating, energizing a transmission island.

[REDACTED] GCC chief: Coordinate between T&D needed.

Bottom line: 11,006 customers out as of call. No timetable

[REDACTED] Fire will continue to move north/northeast and up canyon.

[REDACTED]
PG&E Operations Communications

[REDACTED]
www.pge.com/wildfiresafety

www.pge.com/covid19