
From: [REDACTED]
To: [REDACTED]
Sent: 7/14/2021 2:08:53 PM
Subject: 1400 IC Dixie Fire call

IC [REDACTED] opens call.

230kv tripped at 10:58.

Since then, significant progress on establishment of island. Almost all customers have a generation source. Once the final is in place, that final source will become available.

Distribution just waiting for the final source (East Quincy) to be ready, and then those customers will be restored.

[REDACTED]/Fire update: Not a lot of change as to acres. Continues to burn E/NE away from communities and PG&E assets (so away from Highway 70). Spotting up to half mile away. Fire is now well-established and will continue to burn. Only concern is when shifts around 10 pm when the winds switch directions and start blowing back down canyon.

Next steps: To finalize the island and flip the switch. Restoration takes a little longer to restore with an island vs. a grid.

System shows that all customers are restored

[REDACTED]
PG&E Operations Communications

[REDACTED]
www.pge.com/wildfiresafety

www.pge.com/covid19