

From: [REDACTED]  
 To: [REDACTED]  
 Sent: 7/14/2021 8:13:21 AM  
 Subject: RE: Dixie Fire

PSS is unavailable until about 9 a.m. as he's at a briefing and will call me after. But as you know he feeds the HAWC and anything he'll tell me the HAWC already knows. I'm not getting those texts from the HAWC and no emails on this incident either, but I do get others outside my area.

Here's what I found on ILIS. Note "tree into line" and "CPUC called."

No updates on the local news from their stories last night. Hoping the fire settled with the cooler temps and higher humidity and air attacks can resume this morning.



## Unplanned Outages

### Paradise

<b>Circuit</b>	102211101, BUCKS CREEK-1101	<b>Event Log</b>	21-0089207
<b>Type</b>	Unplanned	<b>Weather</b>	Clear;32-90F
<b>Customers</b>	<a href="#">CESO</a> 4 <a href="#">CEMO</a> 0 <a href="#">ADJ CESO</a> 3 <a href="#">Initial</a> 2	<b>Customer Minutes</b>	<a href="#">Sus</a> 460 <a href="#">Mom</a> 0 <a href="#">Adj Sus</a> 460 <a href="#">CAIDI</a> 153
<b>Active</b>	YES	<b>Fault Type</b>	Line to Line
<b>Interval</b>	Sustained	<b>Action Required</b>	No
<b>EquipID</b>	17733	<b>Construction Type</b>	OH
<b>Equipment Type</b>	Fuse	<b>OIS Outage#</b>	1403761
<b>Equipment Condition</b>	Conductor, Overhead, Normal	<b>Targets</b>	
<b>Crew Notified Time</b>		<b>Supervisor Notified</b>	
<b>Equipment Address</b>	CRESTA DAM TAP W/O SW 17183	<b>Fire Mitigation</b>	No
<b>Fault Location</b>	1ST SPAN LD SIDE OF FUCO 17733		
<b>Previous Switching</b>			
<b>Details</b>	VEG FIRE IN AREA		
<b>Action Description</b>		<b>Wire Down Energized</b>	No
<b>Cause</b>	Vegetation, Tree - fell into line	<b>No Access Reason</b>	
<b>Multi Damage Location</b>	No	<b># of Operations</b>	
<b>Counter Read</b>		<b>Created By</b>	[REDACTED]
<b>Outage Level</b>	Distribution Circuit	<b>Last Updated By</b>	[REDACTED]
<b>FNL</b>	07/13/21 16:40	<b>Reviewed By</b>	Not Required
<b>End Date</b>		<b>Reviewed By Date</b>	

Date	Description	Customers Restored
07/13/21 16:40	FUSE 17733 OPEN [REDACTED] FOUND FUCO 17733 #1 AND #2 BLOWN OPENED REMAINING AND TAGGED MOL -TREE IN THE LINE - GRASS FIRE- CALLED CPUC- D.O. NOTIFIED OF FUSES BLOWN AT 2250	0
07/13/21 20:30	SWITCH 941 OPEN & T/MOL, PER TMAN [REDACTED] CAL FIRE REQUEST TO OPEN SWITCH FOR FIRE IN THE AREA	-1

## Planned Outages

From: [REDACTED]  
 Sent: Wednesday, July 14, 2021 7:47 AM  
 To: [REDACTED]

**Subject:** RE: Dixie Fire

Thanks.

---

**From:** [REDACTED]  
**Sent:** Wednesday, July 14, 2021 7:42 AM  
**To:** [REDACTED]  
**Subject:** RE: Dixie Fire

I'll call the PSS.

---

**From:** [REDACTED]  
**Sent:** Wednesday, July 14, 2021 7:29 AM  
**To:** [REDACTED]  
**Subject:** Dixie Fire

Morning. Let's keep a close watch on this one, and pull together a very high level 2-3 TPs. I did not see any outage in the system around this, but please check. Twitter chatter when it started said it has started "under the powerlines."

[REDACTED]  
PG&E Operations Communications  
[REDACTED]

[www.pge.com/wildfiresafety](http://www.pge.com/wildfiresafety)  
[www.pge.com/covid19](http://www.pge.com/covid19)