

From: [REDACTED]
 To: [REDACTED]
 Sent: 7/14/2021 8:35:27 AM
 Subject: FW: Dixie Fire

I've asked [REDACTED] to keep close tabs on this today. He shares the below.

From: [REDACTED]
 Sent: Wednesday, July 14, 2021 8:13 AM
 To: [REDACTED]
 Subject: RE: Dixie Fire

PSS is unavailable until about 9 a.m. as he's at a briefing and will call me after. But as you know he feeds the HAWC and anything he'll tell me the HAWC already knows. I'm not getting those texts from the HAWC and no emails on this incident either, but I do get others outside my area.

Here's what I found on ILIS. Note "tree into line" and "CPUC called."

No updates on the local news from their stories last night. Hoping the fire settled with the cooler temps and higher humidity and air attacks can resume this morning.

[REDACTED]

Unplanned Outages

Paradise

Circuit	102211101, BUCKS CREEK-1101	Event Log	21-0089207
Type	Unplanned	Weather	Clear;32-90F
Customers	CESO 4 CEMO 0 ADJ CESO 3 Initial 2	Customer Minutes	Sus 460 Mom 0 Adj Sus 460 CAIDI 153
Active	YES	Fault Type	Line to Line
Interval	Sustained	Action Required	No
EquipID	17733	Construction Type	OH
Equipment Type	Fuse	OIS Outage#	1403761
Equipment Condition	Conductor, Overhead, Normal	Targets	
Crew Notified Time		Supervisor Notified	
Equipment Address	CRESTA DAM TAP W/O SW 17183	Fire Mitigation	No
Fault Location	1ST SPAN LD SIDE OF FUCO 17733		
Previous Switching			
Details	VEG FIRE IN AREA		
Action Description		Wire Down Energized	No
Cause	Vegetation, Tree - fell into line	No Access Reason	
Multi Damage Location	No	# of Operations	
Counter Read		Created By	[REDACTED]
Outage Level	Distribution Circuit	Last Updated By	[REDACTED]
FNL	07/13/21 16:40	Reviewed By	Not Required
End Date		Reviewed By Date	

Date	Description	Customers Restored
07/13/21 16:40	FUSE 17733 OPEN- [REDACTED] FOUND FUCO 17733 #1 AND #2 BLOWN OPENED REMAINING AND TAGGED MOL - TREE IN THE LINE - GRASS FIRE- CALLED CPUC- D.O. NOTIFIED OF FUSES BLOWN AT 2250	0
07/13/21 20:30	SWITCH 941 OPEN & T/MOL, PER TMAN [REDACTED] CAL FIRE REQUEST TO OPEN SWITCH FOR FIRE IN THE AREA	-1

Planned Outages

From: [REDACTED]
Sent: Wednesday, July 14, 2021 7:47 AM
To: [REDACTED]
Subject: RE: Dixie Fire

Thanks.

From: [REDACTED]
Sent: Wednesday, July 14, 2021 7:42 AM
To: [REDACTED]
Subject: RE: Dixie Fire

I'll call the PSS.

From: [REDACTED]
Sent: Wednesday, July 14, 2021 7:29 AM
To: [REDACTED]
Subject: Dixie Fire

Morning. Let's keep a close watch on this one, and pull together a very high level 2-3 TPs. I did not see any outage in the system around this, but please check. Twitter chatter when it started said it has started "under the powerlines."

[REDACTED]
PG&E Operations Communications
[REDACTED]

www.pge.com/wildfiresafety

www.pge.com/covid19