

---

**From:** [REDACTED]  
**To:** [REDACTED]  
**Sent:** 7/14/2021 9:56:22 AM  
**Subject:** Dixie Fire report #1

Fire is approximately 1200 acres and 0% contained. Fire is burning in steep and inaccessible terrain north of HWY 70 and west of Merlin, underneath PG&E's Distribution & Transmission line assets. The fire has come out of the Feather River canyon bottom and has reached the ridgetop near the Caribou-Table MTN 230kV lines. The fire is currently burning upslope, upcanyon to the east, northeast under normal diurnal summer time burning conditions. CAL FIRE's attempting to get ground resources to the ridgetop along the 300 U Line road in an attempt to stop the forward rate of spread using dozers and fixed wing aircraft. This fire is very dynamic and lag time for getting ground resources in place will be the challenge for firefighters. Last night at 2030 hours, CAL FIRE requested PG&E to deenergize the Bucks Creek 1101 circuit from SSD T-line Supervisor [REDACTED] is engaged on the scene working with PSS [REDACTED]. SIPT resources are on scene (E-211 and 213) pretreating distribution assets on the Bucks Creek 1101, then later today will begin pretreatment efforts to the west on the Big Bend 1101 from Flea MTN west to the community of Concow. PG&E's GIS Team is working to build a PG&E perimeter map. PSS [REDACTED] will continue to provide remote support for PSS [REDACTED] as there is little to no communications available in the Feather River Canyon.

[REDACTED]  
*Public Safety Specialist, Expert  
Wildfire Operations  
Community Wildfire Safety Program*

**PACIFIC GAS AND ELECTRIC COMPANY**

