
From: [REDACTED]
To: [REDACTED]
Sent: 7/14/2021 1:09:06 PM
Subject: 1300 Dixie Fire Ops update

Lead: IC [REDACTED] GCC

10:58 230kv Caribou-Table Mtn relayed. 11,006 customers out. As of 1300, all 4 generators at Caribou are back in service. Restoration efforts continue with the expectation that other 60kv lines back.

[REDACTED]: No updates. Awaiting air patrol.

[REDACTED], DCC: Only one small distribution move available.

[REDACTED]/PSS: Fire update: Dixie Fire now 2,000+ acres. Push E/NE along the rim. Paralleling the 230kv line. Expect impact to several transmission towers, but not a huge impact so far to our facilities. Burning away from Concow, Pulga and Cresta.

Action item: Continue to build out transmission island. Goal is to have that done "within an hour or so."

[REDACTED]: Be safe.

Bottom line: Customers impacted remain the same, right around 11,000. As noted above, they hope to have something in place in about 60 minutes to allow some restoration. Next call is at 1400.

[REDACTED]
PG&E Operations Communications

[REDACTED]
www.pge.com/wildfiresafety
www.pge.com/covid19