	Native Messages chat (chat191750067180067362) :		
	Starting text group anticipating a request to de energize T line. Meeting with IC in 10. W		
	when request is confirmed and follow up with call to Copy on Signal message re Caribou Table 230kV	11:08 AM	
	Unread	11:09 AM	
	So when you say lots confirming you mean phrase to phase and it will remain out?	11:09 AM	
	It relayed and did not test	11:11 AM	
		11:11 AM	
	They will not re-energize	11:11 AM 11:17 AM	
	They are working on islanding right now	11:18 AM	
	✔ how about the 230 assets in the bottom of the canyon? What's their status?	11:18 AM	
	Still energized	11:20 AM	
,	✓ request may come soon to de-energize. I gave the GCC and a heads up and we'll have y make that call to GCC when the time comes if that works, I'll be on the 11:30 AM GCC Ops call 11:25		
	We're going to leave the two 230kv lines in the canyon energized for now. Leave Caribou Table off.		
	Сору	11:27 AM	
	✓ understood per IC leave the 2 230kV lines in the canyon energized	11:28 AM	

PGE-DIXIE-NDCAL-000022141