

# Central Coast, DeAnza, Diablo, East Bay, Fresno, Humboldt, Kern, Los Padres, Mission, North Bay, North Valley, Peninsula, Sacramento, San Francisco, San Jose, Sierra, Sonoma, Stockton, Yosemite

## Outage Report

Report Printed Fri Jul 23 12:36:32 PDT 2021		
Date From 07/12/2021	Date To 07/13/2021	Outage Type Both
OutNum	Equipment Type	Equip Condition
Equipment Involved	Equipment Cause	Equipment Supplemental
Outage Level	Outage Interval	Fault Type
Action Required Both	Active Both	Circuit BUCKS CREEK-1101
EquipID	Fire Mitigation No	District

[Export To Excel](#)

## Unplanned Outages

### North Valley

### Paradise

<b>Circuit</b>	102211101, BUCKS CREEK-1101	<b>Event Log</b>	21-0089207
<b>Type</b>	Unplanned	<b>Weather</b>	Clear;32-90F
<b>Customers</b>	<a href="#">CESO</a> 7 <a href="#">CEMO</a> 0 <a href="#">ADJ</a> 5 <a href="#">Initial</a> 2 <a href="#">Customer Minutes</a> <a href="#">Sus</a> 4690 0 <a href="#">Adj</a> 4690 <a href="#">CAIDI</a> 938		
			<a href="#">Mom</a> <a href="#">Sus</a>
<b>Active</b>	YES	<b>Fault Type</b>	Line to Line
<b>Interval</b>	Sustained	<b>Action Required</b>	No
<b>EquipID</b>	17733	<b>Construction Type</b>	OH
<b>Equipment Type</b>	Fuse	<b>OIS Outage#</b>	1403761, 1404951
<b>Equipment Condition</b>	Conductor, Overhead, Normal	<b>Targets</b>	
<b>Crew Notified Time</b>		<b>Supervisor Notified</b>	
<b>Equipment Address</b>	CRESTA DAM TAP W/O SW 17183	<b>Fire Mitigation</b>	No
<b>Fault Location</b>	1ST SPAN LD SIDE OF FUCO 17733		
<b>Previous Switching Details</b>	VEG FIRE IN AREA		
<b>Action Description</b>		<b>Wire Down Energized</b>	No
<b>Cause</b>	Vegetation, Tree - fell into line	<b>No Access Reason</b>	Fire Activity
<b>Multi Damage Location</b>	No	<b># of Operations</b>	
<b>Counter Read</b>		<b>Created By</b>	
<b>Outage Level</b>	Distribution Circuit	<b>Last Updated By</b>	
<b>FNL</b>	07/13/21 16:40	<b>Reviewed By</b>	Not Required
<b>End Date</b>		<b>Reviewed By Date</b>	

  

Date	Description	Customers Restored
07/13/21 16:40	FUSE 17733 OPEN-  FOUND FUCO 17733 #1 AND #2 BLOWN OPENED REMAINING AND TAGGED MOL -TREE IN THE LINE - GRASS FIRE- CALLED CPUC- D.O. NOTIFIED OF FUSES BLOWN AT 2250;  HAD ALSO REPORTED THAT THERE WERE MULTIPLE CONSTRUCTION CREWS IN THE AREA WORKING ON THE BRIDGE AND TUNNEL ALL NEAR THE TROUBLE AREA, TOOK AN EXTRA 2 HOURS TO GET AROUND THEM TO GET TO THE LOCATION	0
07/13/21 20:30	SWITCH 941 OPEN & T/MOL, PER TMAN  &  PER CAL FIRE REQUEST TO OPEN SWITCH FOR SAFETY DUE TO A FIRE IN THE AREA	-1
07/14/21 19:59		0

	CAL FIRE IC: [REDACTED] - REQUESTS BUCKS CREEK 1101 OPEN TO DE-ENERGIZE LINE TWD DIXIE FIRE TO SOUTH , CAL FIRE IC PREDICTS FIRE WILL BE APPROACHING BUCKS CREEK 1101 CIR AT APROX 0300 ---- [REDACTED]	
07/14/21 20:00	LINE RECLOSER 1101/2 OPEN (DMS# 1404951)	-2
07/19/21 13:17	[REDACTED] : UPDATED NO ACCESS - Fire Activity	0
07/19/21 13:18	[REDACTED] : UPDATED NO ACCESS - Fire Activity	0